

233/2025
11/9/2025

APPENDIX - XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 233/2025

Dated: 11.09.2025

It is certified that an inspection team headed by Sera Kumar B. Health Inspector
(Name of Officers with designation) from Family Health Centre, Mulakkuzha
(Name of Department/ Office) inspected the S.N. Vidyapeedham, Kotta
(Name & Address of the school) on 11.09.2025 (date of inspection) and found that the
S.N. Vidyapeedham (Name of school) has safe drinking water
facilities for the students and members of staff of the institution and is maintaining the hygienic
sanitation condition in the school building & the campus as per norms prescribed by the Central/
State/ U.T. Govt.

The above is valid for a period of One Year

Signature with Seal: 

Name

Designation

Name & Address of the Office / Department :

PHC, MULAKKUZHA

To


The Principal
S.N. Vidyapeedham, Kotta

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LABORATORY
PULIKKEEZHU, THIRUVALLA

Telephone No. 0469 2999833, Email :kwaqcsdlplkz@gmail.com

TEST REPORT

Report No:3916/PLKZ/08/2025(MB)		Date: 21.08.2025
Customer Name & Address Prabha S Principal SN Vidyapeedom Kotta P O Chengannur	1.Date of Payment Received	19.08.2025
	2. Date of Sample Received	20.08.2025
	3. Time of Sampling	2.51 pm
	4. Sampling done by	Health Inspector,PHC,Mulakkuzha
	5. Sample Code	2025/QCSDL/PLKZ/P 3926
	6. Source of Sample	Drinking Water
	7. Sampling Method	Not Applicable
	8. Sample Quantity	200 ml
	9.Test performing dates	From: 20.08.2025 To: 21.08.2025

BACTERIOLOGICAL ANALYSIS

Sl. No	Parameters	Acceptable limits as per IS 10500 -2012	Test Method	Result
1	Total Coliforms	Shall not be detected/100 ml	IS 15185 : 2016(Reaffirmed 2021)	ABSENT
2	<i>E. coli</i>	Shall not be detected/100 ml	IS 15185 : 2016(Reaffirmed 2021)	ABSENT

Remarks: -

NB: -The results stated above related only to the sample(s)submitted for testing. This test Certificate shall not be reproduced except in full without the written approval of the Laboratory.

Verified By

Name: Deepa Raj C.S

Bacteriologist

Page 1/1

QUALITY CONTROL SUB DISTRICT LABORATORY
KERALA WATER AUTHORITY
PULIKKEEZHU, THIRUVALLA

** End of Report **